



### CERTIFICATE OF COMPLIANCE


REPORT NUMBER: CC032910

Date: March 29, 2010

This certifies that this product, provided by Triangle Fastener Corporation, meets the following requirements;

Product: Miami-Dade Approved CONCEALOR® Low Profile Head Screws.

<u>Size</u>	<u>Miami-Dade File No.</u>
#10-13 x 1" GP	10-0223.08
#10-13 x 1-1/2" GP	10-0223.08
#12-11 x 1" GP	10-0223.07
#12-14 x 1" DP3	10-0223.09
#12-14 x 1 1/2" DP3	10-0223.09



Material: Carbon Steel

Finish: .0003" Zinc & Yellow TRI-SEAL™ Coating  
Salt Spray: 1,000 hours

Performance: The screws were independently tested and passed a stringent 1,000 hours salt spray test per ASTM G-85 Annex 5.



Country of Origin: Taiwan

Approved:   
 Joe Stager  
 VICE PRESIDENT  
 Product Development and Marketing

DISCLAIMER: THIS INFORMATION IS FOR GENERAL INFORMATION ONLY AND CANNOT BE CONSTRUED AS A SUBSTITUTE FOR COMPETENTPROFESSIONAL ADVISE OR SERVICE. ANY PARTY CONSIDERING APPLICATION OR USE DOES SO AT THEIR OWN RISK AND ASSUMES ANY AND ALL RESULTING LIABILITY FROM THIS APPLICATION OR USE.

**Listed Product  
Certificate**

**MIAMI-DADE COUNTY  
APPROVED**



Miami-Dade County, Florida  
Building Code Compliance Office  
140 West Flagler Street, Suite 1603  
Miami, Florida 33130-1563  
Tel (305)375-2901 Fax (305)375-2908

**Certification No. L 10-0223.08**

**Ref.: Triangle Fastener Corporation  
6800 Suemal Place  
Jacksonville, FL 32254**

**The Building Code Compliance Office certifies that the above referenced manufacturer has submitted evidence to the Product Control Division to participate in its Listing Service Program. The scope of this certificate is limited to the corrosion-resistance of the product(s) listed herein.**

**#10-13 Double Lead Gimlet Point**

**Any product listed under this certificate may be subject to audits conducted by the Quality Assurance Unit of the Product Control Division. As part of the audit program, random samples, obtained from a supply house may be sent to a Miami-Dade County approved laboratory to ensure product conformity. Any complaint submitted to our office and supported by evidence will be investigated and may result in testing of the product. A listed product will not be tested more than twice for the same issue within the terms of the certification.**

***Certification Approval Date: 3/11/2010***

***Certification Expire: 3/11/2015***

A handwritten signature in black ink, appearing to read "Jaime D. Gascon".

**Jaime D. Gascon, P.E.  
Chief  
Product Control Division**

A handwritten signature in black ink, appearing to read "Americo Segura".

**Americo Segura  
BCCO- Quality Assurance Supervisor  
Product Control Division**

Miami-Dade County's Building Code Compliance Office reserves the right to revoke this certification for noncompliance issues related to the Product Listing requirements and/or noncompliance issues related to the manufacturer's quality assurance program.

**Listed Product  
Certificate**

**MIAMI-DADE COUNTY  
APPROVED**



Miami-Dade County, Florida  
Building Code Compliance Office  
140 West Flagler Street, Suite 1603  
Miami, Florida 33130-1563  
Tel (305)375-2901 Fax (305)375-2908

**Certification No. L 10-0223.07**

**Ref.: Triangle Fastener Corporation  
6800 Suemal Place  
Jacksonville, FL 32254**

**The Building Code Compliance Office certifies that the above referenced manufacturer has submitted evidence to the Product Control Division to participate in its Listing Service Program. The scope of this certificate is limited to the corrosion-resistance of the product(s) listed herein.**

**#12 Concealor GP (12-11 x 1" and 1-1/2")**

**Any product listed under this certificate may be subject to audits conducted by the Quality Assurance Unit of the Product Control Division. As part of the audit program, random samples, obtained from a supply house may be sent to a Miami-Dade County approved laboratory to ensure product conformity. Any complaint submitted to our office and supported by evidence will be investigated and may result in testing of the product. A listed product will not be tested more than twice for the same issue within the terms of the certification.**

**Certification Approval Date: 3/11/2010**

**Certification Expire: 3/11/2015**

A handwritten signature in black ink, appearing to read "Jaime D. Gascon".

**Jaime D. Gascon, P.E.  
Chief  
Product Control Division**

A handwritten signature in black ink, appearing to read "Americo Segura".

**Americo Segura  
BCCO- Quality Assurance Supervisor  
Product Control Division**

Miami-Dade County's Building Code Compliance Office reserves the right to revoke this certification for noncompliance issues related to the Product Listing requirements and/or noncompliance issues related to the manufacturer's quality assurance program.

**Listed Product  
Certificate**



**Miami-Dade County, Florida**  
Building Code Compliance Office  
140 West Flagler Street, Suite 1603  
Miami, Florida 33130-1563  
Tel (305)375-2901 Fax (305)375-2908

**Certification No. L 10-0223.09**

**Ref.: Triangle Fastener Corporation**  
6800 Suemal Place  
Jacksonville, FL 32254

**The Building Code Compliance Office certifies that the above referenced manufacturer has submitted evidence to the Product Control Division to participate in its Listing Service Program. The scope of this certificate is limited to the corrosion-resistance of the product(s) listed herein.**

**#12 Concealor DP3 (12-14 x 1" and 1-1/2")**

**Any product listed under this certificate may be subject to audits conducted by the Quality Assurance Unit of the Product Control Division. As part of the audit program, random samples, obtained from a supply house may be sent to a Miami-Dade County approved laboratory to ensure product conformity. Any complaint submitted to our office and supported by evidence will be investigated and may result in testing of the product. A listed product will not be tested more than twice for the same issue within the terms of the certification.**

***Certification Approval Date: 3/11/2010***

***Certification Expire: 3/11/2015***

A handwritten signature in black ink, appearing to read "Jaime D. Gascon".

**Jaime D. Gascon, P.E.**  
Chief  
Product Control Division

A handwritten signature in black ink, appearing to read "Americo Segura".

**Americo Segura**  
BCCO- Quality Assurance Supervisor  
Product Control Division

Miami-Dade County's Building Code Compliance Office reserves the right to revoke this certification for noncompliance issues related to the Product Listing requirements and/or noncompliance issues related to the manufacturer's quality assurance program.